

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-011030 Permit # 01314-2008INS Request Rec'd 08/05/2008 Amended Date Approval Date 8/6/2008 JC Permit Expires 2/6/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:

Exxon Mobil Oil Corporation

7300 West Friendly Avenue, P.O. Box 22087, CMS Mailstop F-76

Greensboro, NC 27420-2087

Contact: GVR Compliance Analyst (800) 253-8054

(2) FACILITY - name and address where tanks are located:

Mobil Oasis Eastbound / Northbound 4100 Denley Road, Tri-State Toll I-294 Mile Post 38.0 Schiller Park, Cook Co., IL

Contact: Eric McPhee (303) 986-8011

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 2579) 10,000 gallons
- (b) Type of tanks: (TK # 2579) (Installing) Containment Solutions double wall fiberglass brine filled
- (c) Type of piping: (TK # 2579) (Installing) OPW 4" secondary duct piping, (TK # 2579) (Installing) OPW Flexworks CP-15 double wall non corrosive flexible product piping
- (d) Product to be stored in each tank: (TK # 2579) E-85
- (e) Type of leak detection being used:

Tank: (TK # 2579) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor, (TK # 2579) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge

Piping: (TK # 2579) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 2579) - (Installing) Veeder Root TLS350 mag piping sump sensors at all dispenser sumps and all submersible sumps

(f) Corrosion Protection being used:

Tank: (TK # 2579) - (Installing) Fiberglass

Piping: (TK # 2579) - (Installing) Non-corrosive flexible, (TK # 2579) - (Installing) Fiberglass secondary containment

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS:**
- (6) SPECIAL CONTINGENCIES:

Contact Person: Doug Harmon

Phone:

Contractor Registration # IL-194 Exp. 06/21/2010

Sincerely,

Janu J Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)