



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-044137
Permit # 01290-2008INS
Request Rec'd 08/04/2008
Amended Date
Approval Date 8/4/2008 JC
Permit Expires 2/4/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Costco Wholesale Corporation 999 Lake Drive Isaquah, WA 98027 Contact: Paul Gorton	(2) FACILITY - name and address where tanks are located: Costco Gasoline 221 South Randall Road St Charles, Kane Co., IL Contact:
--	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 1, 2, 3) - 20,000 gallons
- (b) **Type of tanks:** (TK # 1, 2, 3) - (Installing) XERXES double wall fiberglass brine filled
- (c) **Type of piping:** (TK # 1, 2, 3) - (Installing) A.O. Smith double wall fiberglass (including a siphon bar between tank #1 & #2).
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline
- (e) **Type of leak detection being used:**
Tank: (TK # 1, 2, 3) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor, (TK # 1, 2, 3) - (Installing) Veeder Root TLS350 automatic tank gauge
Piping: (TK # 1, 2, 3) - (Installing) Veeder Root TLS 350 discrim cont sump interstitial sensor at each submersible sump only, (TK # 1, 2, 3) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 1, 2, 3) - (Installing) Veeder Root TLS 350 non-discriminating interstitial piping sump sensor at each dispenser sump only
- (f) **Corrosion Protection being used:**
Tank: (TK # 1, 2, 3) - (Installing) Fiberglass
Piping: (TK # 1, 2, 3) - (Installing) Fiberglass
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Jack Meck Phone: Contractor Registration # IL-881 Exp. 10/27/2009

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)