



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-025605
Permit # 01276-2008UPG
Request Rec'd 07/29/2008
Amended Date
Approval Date 7/30/2008 JC
Permit Expires 1/30/2009

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: PACE Suburban Bus 550 W. Algonquin Road Arlington Heights, IL 60005 Contact: David Szaflarski (847) 228-4228	(2) FACILITY - name and address where tanks are located: PACE River Division 975 S. State, Route 31 Elgin, Kane Co., IL Contact: David Szaflarski (847) 228-2453
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 20,000 gallons
- (b) **Type of tanks:** (TK # 1) - Existing single wall fiberglass
- (c) **Type of piping:** (TK # 1) - Existing non-corrosive flexible from one of the tank sumps to the generator (one suction supply line and one return line), (TK # 1) - Existing double wall fiberglass for the dispensers
- (d) **Product to be stored in each tank:** (TK # 1) - Diesel Fuel
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 1) - Existing automatic tank gauging
 - Piping:** (TK # 1) - (Installing) Red Jacket FX2D mechanical line leak detector, (TK # 1) - Existing European Suction for the generator supply line, (TK # 1) - Existing interstitial monitoring at all submersible sumps, dispenser sumps and transition sumps
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 1) - Existing fiberglass
 - Piping:** (TK # 1) - Existing non-corrosive flexible, (TK # 1) - Existing fiberglass
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** See also permit #01275-2008UPG for a similar situational reference to facility #2-013288.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Jim Veverka Phone: (630) 530-9880 Contractor Registration # IL-1733 Exp.

Sincerely,

