



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
Facility # 6-003275
Permit # 00088-2013REM
Request Rec'd 02/01/2013
Amended Date
Approval Date 2/1/2013 JC
Permit Expires 8/1/2013

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>St. Elizabeth Hospital 211 S. 3rd Street Belleville, IL 62222</p> <p>Contact: Ramsae Stricker (618) 234-2120</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>St. Elizabeth Hospital 211 S. 3rd Street Belleville, St. Clair Co., IL</p> <p>Contact: Ramsea Stricker (618) 234-2120 Ext. 1123</p>
--	---

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 5) - 20,000 gallons
- (b) *Description/location of piping being removed:*
- (c) *Product stored in each tank:* (TK # 5) - Fuel Oil
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 5)

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES: This permit replaces permit #01070-2012REM. This permit is for removal of the tank and only a partial amount of the piping that is in the local area of the tank itself. See permit #01060-2012INS (tank #6) for a more comprehensive review of this job (The installation of tank #6 will involve connecting the existing piping associated with tank #5, to the new tank #6 - approximately 10' will be installed via the install permit to connect to the existing European suction piping).

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Neumayer Equipment Company, Inc. 5060 Arsenal Street Saint Louis, MO 63139</p>	<p>Contact Person: Rick McKay Phone: Contractor Registration # Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)