



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 1027652
Permit # 00178-2019UPG
Request Rec'd 01/21/2019
Amended Date
Approval Date 1/23/2019 DS
Permit Expires 7/23/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Stephenson Service Company 410 S. Hancock Ave. Freeport, IL 61032</p> <p>Contact: Gordy Williams (815) 235-7400</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Freeport Fast Stop Express 1641 Sleezer Home Drive Freeport, IL 61032</p> <p>Contact: Mary Mouring (815) 235-7400</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - E-85, (TK # 2, 3) - Gasoline, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4) Overfill Prev Device - Overfill Alarm Veeder Root TLS 300i*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Remove and replace over fill valves at (4) tanks with drop tubes. Install Veeder Root overfill alarm with acknowledgement box

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Howard Lee &amp; Sons Inc. 4093 Perryville Road PO Box 446 Cherry Valley, IL 61016</p>	<p>Contact Person: Vicky Buhl Phone: (815) 332-4966 Contractor Registration # IL456 Exp. 3/20/2020</p>

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File