



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2041196
Permit # 00179-2019UPG
Request Rec'd 01/23/2019
Amended Date
Approval Date 1/23/2019 DS
Permit Expires 2/5/2019

Permit for Emergency Repair Request on 1/22/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Delta Sonic Car Wash Systems, Inc. 570 Delaware Avenue Buffalo, NY 14202 Contact: Brad Natilizia (716) 541-2178</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Delta Sonic Car Wash(Citgo) 1812 West Jefferson Street Joliet, IL 60540 Contact: Chuck Mikolainis (815) 207-7000</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 12,500, (TK # 4) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 4) Piping - Flexible Double Wall OPW Flexworks, (TK # 1, 2, 4) Piping - Shear Valves, (TK # 1, 2, 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1, 2, 4) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : The fuel island was destroyed by a vehicle. We are installing new dispenser containment sump, new dispenser, new shear valve, new flex connector and new concrete fuel island. We are replacing any damaged piping with new OPW flex pipe.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street

Contact Person: Robert Stenstrom
Phone: (815) 398-6250

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File