



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2009106
Permit # 00131-2019UPG
Request Rec'd 01/17/2019
Amended Date 01/30/2019 DS
Approval Date 1/17/2019 DS
Permit Expires 7/17/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Prashant Nair 3201 N. Lewis Ave. Waukegan, IL 60087</p> <p>Contact: Prashant S. Nair (312) 978-0039</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Euclid Shell 1950 Plum Grove Road Rolling Meadows, IL 60008</p> <p>Contact: Prashant Nair (312) 878-0039</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2) - 8,000, (TK # 3) - 6,000

(b) Type of tanks:

(c) Type of piping: (TK # 1, 2, 3) Piping - Other Steel Riser

(d) Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 2, 3) - Gasoline - Regular

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket OPW 1-2100C DEVR

(h) Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Note OPW 61SOC drop tubes are shown of the approved permit. OPW 71SO-400C drop tubes were actually installed. Please revise this permit to show the 71SO tubes were installed at this site. **NOTE: System shows ball floats are existing but contractor says there are none which is why the site was written up.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company

Contact Person: Ed Angell

2939 175th Street
Lansing, IL 60438

Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", written in black ink on a white background. The signature is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File