



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7020755
Permit # 00227-2019UPG
Request Rec'd 02/01/2019
Amended Date
Approval Date 2/4/2019 DS
Permit Expires 8/6/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: J.D. Streett & Company, Inc. 144 Weldon Parkway Maryland Heights, MO 63043 Contact: Darrell Meek (800) 678-6600	(2) <u>FACILITY</u> - name and address where tanks are located: Johnston City ZX 709 North Grand Johnston City, IL 62951 Contact: Kandra Gourley (618) 983-5626
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7, 8) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7) Piping - Other Steel Riser, (TK # 8) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 8) Piping - Other submersible pump, (TK # 8) Piping - Ball Valves, (TK # 8) Piping - Flex Connector Steel, (TK # 8) Piping - Single Wall Submersible (STP) Sump Petroleum Containment Inc. 4500 Series*
- (d) Product to be stored in each tank: (TK # 7) - Gasoline, (TK # 8) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 8) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 7) Spill Contain Device - Double Wall Spill Bucket Franklin Fueling Systems Defender 705*
- (h) Overfill prevention devices: (TK # 7) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Install new dispensers on the existing island forms. Install new spill bucket, riser pipe and overfill drop tube on the Premium UL tank. Install new submersible pump and and containment sump on the Diesel tank. New flex connector and ball valve will be installed. The existing single wall fiberglass pipe will be cut back. modified as requirerd and re-installed into the containment sump to connect to the submersible pump. A new mechanical leak detector will be installed on the Diesel.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Harvey Stokes
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File