



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

| |
|----------------------------|
| FOR OFFICE USE ONLY |
| Facility # 3018330 |
| Permit # 00244-2019UPG |
| Request Rec'd 01/14/2019 |
| Amended Date |
| Approval Date 2/5/2019 DS |
| Permit Expires 8/6/2019 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Metropolitan Airport Authority 2430 69th Ave. Box 9009 Moline, IL 61265</p> <p>Contact: Bradley Gantt (309) 764-9621</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Quad City Airport 2200 69th Ave. Moline, IL 61265</p> <p>Contact: Bill Theofilis (309) 764-9621</p> |
|--|---|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 13, 14) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 13) - Diesel Fuel, (TK # 14) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 13, 14) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 Evo , (TK # 13) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Incon TSP- HIS Brite , (TK # 14) Leak Detect - Tank - Interstitial Monitoring Incon TSP HIS , (TK # 14) Leak Detect - Tank - Interstitial Monitoring Incon TSP ULS*
 - Piping: (TK # 13, 14) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Incon TSLS 500 , (TK # 13, 14) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Incon*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 13, 14) Overfill Prev Device - Overfill Alarm Incon TS-RA2*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Upgrade atg to Evo 550

| | |
|---|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Illowa Enterprises, Inc. 2703 4th Avenue | Contact Person: Rob Vyncke Phone: (309) 762-1729 |

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File