



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1013230
Permit # 00261-2019REM
Request Rec'd 02/06/2019
Amended Date
Approval Date 2/7/2019 DS
Permit Expires 8/7/2019

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>United Parcel Service 2100 N. Hicks Rd. Palatine, IL 60074</p> <p>Contact: John Vlahos (630) 628-2496</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>United Parcel Service 103 N. Commercial Freeport, IL 61001</p> <p>Contact: Joe Tennant (815) 233-2615</p>
--	--

(3) **REMOVAL OF PIPING:**

(a) *Description/location of piping being removed:*

(b) *Which tank(s) are associated with the piping being removed: (TK # 3) - 10,000*

(c) *Reason of piping being removed:*

(d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Remove entire run of pipe between STP sump and dispenser. During excavation for a sump installation, piping was found to be single wall fiberglass in a flexible piping chase; the interstice will not hold pressure. The facility has elected to remove the 15' section of pipe and replace with double wall Ameron 3000LCX while area is excavated. No release is suspected.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 3/7/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File