



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5031907
Permit # 00392-2019UPG
Request Rec'd 03/05/2019
Amended Date
Approval Date 3/5/2019 DS
Permit Expires 9/5/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>FedEx Freight, Inc. 2200 Forward Drive, DC: 2219 Harrison, AR 72601 Contact: Brenden Rose (870) 365-4087</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>FedEx Freight, Inc.-LIN 151 Olson Drive Lincoln, IL 626569792 Contact: Lloyd Noyes (870) 365-4087</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC from existing tank to new dispensers, (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring Veeder Root TLS 350 micro sensor*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing old product lines and dispenser sumps. Installing new APT sumps at dispensers. Will be pulling new 1-1/2" APT product piping through the existing chase piping. Universal shear valves. Installing sump sensors under dispensers an in submersible sump in not already existing. To be completed in 2 phases and inspected in 2 phases.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Jim Scott

W J Scott Company
3861 Tozer Road
Springfield, IL 62707

Phone: (217) 787-6081
Contractor Registration # IL1949 Exp. 4/18/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File