



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174 issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Graham Enterprise, Inc. 750 Bunker Ct., Suite 100 Vernon Hills, IL 60061  Contact: Matthew Graham (847) 837-0777	<b>(2) FACILITY</b> - name and address where tanks are located:  Lake Street BP @ 83 (GEI-160) 1275 North US 83 Grayslake, IL 60060  Contact: Lorraine Pempek (847) 837-0777
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 1, 2, 3) Leak Detect - Piping - Piping Sump Sensors Not Regulated*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank For required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

REMOVE EXISTING SENSORS IN DISPENSER PANS  
REMOVE EXISTING SENSORS IN FILL SUMPS ONLY

Ray spoke to Fred on 3/6/19 and the sensors here are not used for interstitial monitoring of the DW piping. They are to be removed.


**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.  
600 East Joe Orr Road  
Chicago Heights, IL 60411

Contact Person: Douglas Harmon  
Phone: (708) 758-3222  
Contractor Registration # IL194 Exp. 3/10/2020

---

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File