



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 7042092
Permit # 02007-2018UPG
Request Rec'd 12/19/2018
Amended Date 03/07/2019 DS
Approval Date 12/19/2018 DS
Permit Expires 6/19/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 Oklahoma City, OK 73120</p> <p>Contact: Kyle Collins (405) 834-0311</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Love's Travel Stop #318 202 North Ave. Ina, IL 62846</p> <p>Contact: Tabatha Chambelain (405) 302-6640</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 6) - 20,000, (TK # 4) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4, 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 3, 4, 6) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 3) - Diesel Fuel, (TK # 4, 6) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3, 4, 6) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root. NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


The scope of work consists of the addition of (2) new dispenser islands and addition to the existing canopy. The new piping will be Ameron 2 LCX frp piping connected to the existing Ameron 3" over 2" frp piping. The new dispenser sumps will be Bravo 1000 series dispenser sumps. There will be V/R #794380-208 piping sump sensors installed in the (2) new dispenser sumps and connected to the existing V/R TLS 350. The existing mechanical line leak detectors to remain. Revising the piping layout due to natural gas line and conduits. **NOTE: Per Chris Epkins on 3/7/19 all violations for the active NOV have been complied except for the ATG cap which will be rectified before the final.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File