



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6032570
Permit # 00487-2019UPG
Request Rec'd 03/08/2019
Amended Date
Approval Date 3/18/2019 DS
Permit Expires 9/18/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Charlene Troyer (331) 251-7343</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #1456 716 West St. Louis Avenue East Alton, IL 62024</p> <p>Contact: (618) 258-4877</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Flexible Double Wall OPW Flexworks, (TK # 3) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping*
- (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Changing tank #3 to diesel, dispensers 1/2 and 9/10 will be only diesel dispensers on this site.

Install product pipe in existing chase pipe from dispenser 1/2 to 3/4 for tank #1 Nolead, change elbow on this line below dispenser 3/4 to a T and then elbow up to new dispenser at 1/2.

Install product pipe in existing chase pipe from dispenser 11/12 to 9/10 for tank #2 Nolead, change elbow on this line below dispenser 11/12 to a T and then elbow up to new dispenser at 9/10.

Disconnect siphon from tank #3 which will become Diesel fuel and cap siphon pipe and extractor valve.


Install 8 new dispensers, 6 to be 3+0 and 2 to be 3+1. **NOTE: Site has existing sumps and sensors. Existing N.O.V. being addressed under permit 00289-2019UPG. A notification form must be submitted to change the product to Diesel**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File