



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3014321
Permit # 00495-2019REM
Request Rec'd 03/18/2019
Amended Date
Approval Date 3/18/2019 DS
Permit Expires 9/18/2019

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Genesis Medical Center 801 Illini Drive Silvis, IL 61282</p> <p>Contact: Joe Seier (309) 281-4930</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Genesis Medical Center 801 Illini Drive Silvis, IL 61282</p> <p>Contact: Joe Seier (309) 281-4930</p>
--	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 2) - 1,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 2) - Diesel Fuel*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 2) - 3/5/2019*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

The following procedures will be used for the removal of the UST:
Set up exclusion zone, and vacuum pump the remaining diesel fuel from the UST. Using 4 gas meter to monitor the tank atmosphere, EMS, Inc. will inert the UST with CO2 to reach the tank atmosphere (LEL) 5% or less and the Oxygen reach level of 5 % or less to remove the UST from underground and have holes cut at both ends. Monitoring the UST will occur at 3 levels: top, middle, and bottom. Once hole are cut, EMS, inc. will triple rinse the interior of the UST with supplied fresh air respirators. Finally EMS, Inc. will issue clean tank certificate after tank cleaning procedures completed.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Environmental Management Services, Inc.
1030 South Rolff Street
Davenport, IA 52802

Contact Person: Aaron Kaffenberger
Phone: (563) 322-9000
Contractor Registration # IL842 Exp. 9/16/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File