



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 3001346
Permit # 00499-2019UPG
Request Rec'd 03/18/2019
Amended Date
Approval Date 3/18/2019 DS
Permit Expires 9/19/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>7-Eleven, Inc. 3200 Hackberry Road - Gas Compliance Irving, TX 75063  Contact: Scott Thomas Johnson (847) 608-1136</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>7-Eleven Store #34466 4720 27th Street Moline, IL 61265  Contact: Shaygria Seawright (847) 608-1136</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 11) - 10,000, (TK # 7, 12) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 6, 7, 12) - Gasoline, (TK # 11) - Diesel Fuel*
- (e) Type of leak detection being used:*  
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*  
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7, 11, 12) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3112D Edge*
- (h) Overfill prevention devices: (TK # 6, 7, 11, 12) Overfill Prev Device - Overfill Drop Tube Valve OPW 7ISO-4010*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Installation of new OPW Edge double wall spill containments and OPW overfill prevention drop tubes at site. All tanks.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313</p>	<p>Contact Person: Keri Hankins Phone: (816) 761-1270 Contractor Registration # IL598 Exp. 2/23/2020</p>

Sincerely,

*Daniel H. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File