



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-008554
Permit # 01268-2008CAT
Request Rec'd 07/29/2008
Amended Date
Approval Date 7/30/2008 JC
Permit Expires 1/30/2009

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Erica Citgo 1925 Green Bay Road Evanston, IL 60201 Contact: Hausselet Elpenord (847) 864-0900	(2) FACILITY - name and address where tanks are located: Erica Citgo 1925 Green Bay Road Evanston, Cook Co., IL Contact: Hausselet Elpenord (847) 864-0900
---	---

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 1) - 10,000 gallons, (TK # 2, 3, 4) - 5,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3, 4) - Existing single wall steel (**see contingencies**)
- (c) *Type of piping:* (TK # 1, 2, 3, 4) - Existing double wall fiberglass (**see contingencies**)
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank: (TK # 1) - Existing fiberglass or possibly lined (**see contingencies**), (TK # 2, 3, 4) - Existing interior lining
Piping: (TK # 1, 2, 3, 4) - (**Installing**) **Impressed Current cathodic protection to be installed; however, the contingencies for this permit must be viewed carefully to determine the material of construction of tank #1, and to verify the material of construction of the product piping for all these tanks - this permit may have to be amended if necessary, to reflect exactly what is going on at this facility,** (TK # 1, 2, 3, 4) - Existing fiberglass (**see contingencies**)
- (g) *NACE certified designer:* Kristine Michels *Certification number:*
- (h) *Method of integrity assessment of tank(s) being used:*

- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** See also permit #00737-2008LIN from Chicago Tank Lining Inc. for further reference.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Mark Austin Phone: (630) 483-2500 Contractor Registration # IL-311 Exp.
--

Sincerely,

