



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022831
Permit # 00539-2019UPG
Request Rec'd 03/21/2019
Amended Date
Approval Date 3/21/2019 DS
Permit Expires 9/23/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Harlem Division 1201, LLC 1201 N. Harlem Ave. Oak Park, IL 60302 Contact: Robert Sloan (708) 848-7770</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>BP 1201 N. Harlem Avenue Oak Park, IL 60302 Contact: Robert Sloan (708) 848-7770</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5) Piping - Fiberglass Single Wall Piping Ameron*

(d) *Product to be stored in each tank: (TK # 5) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : During testing to reopen this site a leak was found in the rEgular single wall pipe 48" outside of dispenser #5/6. The piping will be repaired with single wall fiberglass pipe. **NOTE: Per STSS Carben, the NOV issue with the shear valves not at grade was satisfied when the contractor lowered the islands and Ed Angell submitted a like for like replacement form on 9-25-18 to replace the spill containment devices and the passing tests were submitted 9-26-18 which will satisfy the N.O.V.**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File