



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 3127453152

<p><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 2023203          Permit # 00540-2019UPG          Request Rec'd 03/21/2019          Amended Date          Approval Date 3/22/2019          Permit Expires 9/24/2019</p>
--

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>KCMK Corp.          342 E. 35th Street          Chicago, IL 60616</p> <p>Contact: Francic Kizakkekuttu (847) 736-0438</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>BP Amoco 18654          342 East 35th Street          Chicago, IL 60616</p> <p>Contact: Francis Kizhakkekuttu (312) 842-9333</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000, (TK # 3) - 12,000*

*(b) Type of tanks:*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*

*(e) Type of leak detection being used:*

*Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containmnt devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>B &amp; K Equipment Company          2939 175th Street          Lansing, IL 60438</p>	<p>Contact Person: Ed Angell          Phone: (708) 474-3344          Contractor Registration # IL1207 Exp. 2/14/2020</p>
---	--

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File