



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2017664  
Permit # 00563-2019UPG  
Request Rec'd 03/22/2019  
Amended Date  
Approval Date 3/25/2019 DS  
Permit Expires 9/25/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Deen, Ltd 503 Mannheim Rd. Bellwood, IL 60104</p> <p>Contact: Mohamed Siraj (773) 552-1355</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Deen, Ltd d/b/a Marathon 503 Mannheim Road Bellwood, IL 60104</p> <p>Contact: Shakeel Khan (773) 562-1355</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall NUPI Smartflex from existing tanks to existing dispensers, (TK # 1, 2, 3) Piping - Single Wall STP/Tanktop Sump Bravo B-407-RB*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline, (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Gilbarco EMC with CSLD*
- Piping: (TK # 1, 2, 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD, (TK # 1, 2, 3) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in submersible and dispenser sumps. NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : We are replacing piping and containment. Existing Spill and overfill to remain.

**NOTE: A removal permit must be obtained to remove the existing piping per 175.300 k) 3)**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Cardinal Compliance LLC

Contact Person: Chris Derro

730 Creel Dr  
Wood Dale, IL 601910000

Phone: (708) 452-8620  
Contractor Registration # IL002418 Exp. 3/18/2021

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File