



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2046794
Permit # 00572-2019REM
Request Rec'd 03/25/2019
Amended Date
Approval Date 3/26/2019 SB
Permit Expires 9/26/2019

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 7353 Grand, LLC 3009 W. Montrose Ave Chicago, IL 60618 Contact: Bart Pzryjemski (773) 202-9819	(2) FACILITY - name and address where tanks are located: Development 7353 West Grand Avenue Elmwood Park, IL 60707 Contact: George Kobylarcik (708) 225-1115
---	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 3, 4) - 4,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 3, 4) - Gasoline - Non Ethanol*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2019-0255*
- (f) *Date each tank was last used: (TK # 3, 4) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Excavate to expose tanks. Pump liquids from tanks. Vent or purge tanks. Check LEL. When LEL or % O2 is 5% or less, excavate to free tank. Lift tanks from excavation and place on poly. Recheck LEL or % O2 when 5% or less cut an opening in tanks and clean tanks-use non sparking tools. Drum tank scrapings. Place tanks on trailer and transport to scrap yard. Back-fill excavation.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Environmental Protection Industries, Inc.
16650 South Canal Street
South Holland, IL 60473

Contact Person: Eryn Barba
Phone: (708) 225-1115
Contractor Registration # IL564 Exp. 6/27/2020

Sincerely,

Shelly Bradley

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File