



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022344
Permit # 00588-2019UPG
Request Rec'd 03/25/2019
Amended Date
Approval Date 3/28/2019 DS
Permit Expires 9/30/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Governors State University University Parkway & Governors Highway University Park, IL 60466 Contact: Carolyn Johnson (708) 534-4515	(2) <u>FACILITY</u> - name and address where tanks are located: Governors State University University Parkway & Governors Highway University Park, IL 60466 Contact: Carolyn Johnson (708) 534-4515
--	--

(3) **UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 4,000, (TK # 3, 4) - 550*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 2, 3, 4) Piping - Other Steel Riser*

(d) *Product to be stored in each tank: (TK # 2, 3) - Gasoline, (TK # 4) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank: (TK # 2, 3, 4) Leak Detect - Tank - Generic Vapor Monitoring Veeder Root TLS350

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Replacing fill and probe risers on each of the 3 tanks listed on this permit application. Risers are being removed so overfill drop tubes that are stuck in the fill risers can be removed and replaced. **NOTE: Vapor monitoring being removed at this facility Pursuant to section 175.630 d) 10)** Phase out and elimination of vapor monitoring pursuant to Subpart I, no permits for installation of vapor monitoring systems will be issued after October 13, 2018. Except pursuant to Subpart I, this method will no longer be allowed for tanks after October 13, 2023.?. **Site has existing ATG.**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File