



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2046697
Permit # 00605-2019INS
Request Rec'd 03/29/2019
Amended Date
Approval Date 4/1/2019 DS
Permit Expires 10/1/2019

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Contact: Eric M. Swaisgood (937) 863-6513	(2) FACILITY - name and address where tanks are located: Speedway #7764 1031 E Main Street East Dundee, IL 60118 Contact: Eric Swaisgood (937) 863-6513
---	--

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 1, 2) - 6,000, (TK # 3) - 12,000, (TK # 4, 5, 6, 7) - 20,000, (TK # 8) - 10,000*
- (b) *Type of tank(s): (TK # 1, 2, 3, 4, 5, 6, 7, 8) Tank - Fiberglass Double Wall Containment Solutions*
- (c) *Type of piping: (TK # 1, 2, 3, 4, 5, 6, 7, 8) Piping - Fiberglass Single Wall Piping Ameron 4000 L single wall vent, (TK # 1, 2, 3, 4, 5, 6, 7) Piping - Flexible Double Wall Franklin Fueling Systems UPP, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Piping - Ball Valves, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Piping - Extractor Fitting Valves, (TK # 1, 2, 3, 4, 5, 6, 7) Piping - Flex Connector Steel, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Piping - Single Wall STP/Tanktop Sump Containment Solutions Fiberglass, (TK # 8) Piping - Flexible Single Wall Piping OmegaFlex DEF-Trac non-corrosive flexible*
- (d) *Product to be stored in each tank: (TK # 1, 4, 5) - Gasoline, (TK # 2) - E-85, (TK # 3, 6, 7) - Diesel Fuel, (TK # 8) - Diesel Exhaust Fluid (Non-Regulated)*
- (e) *Type of leak detection being used:*
Tank: (TK # 1, 2, 3, 4, 5, 6, 7, 8) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus
Piping: (TK # 1, 2, 3, 4, 5, 6, 7) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)
- (f) *Corrosion Protection being used:*
Tank: (TK # 1, 2, 3, 4, 5, 6, 7, 8) Corrosion Prot - Tank - Fiberglass Non-Corrosive
Piping: (TK # 1, 2, 3, 4, 5, 6, 7, 8) Corrosion Prot - Piping - Flexible Non-Corrosive
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3, 4, 5, 6, 7) Spill Contain Device - Single Wall Spill Bucket OPW 1C-3101DEV, (TK # 8) Spill Contain Device - Field Constructed*
- (h) *Overfill prevention devices: (TK # 1, 3, 4, 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Overfill Prev Device - Overfill Alarm Veeder Root TLS 450plus, (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SOM*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in

diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.


(6) SPECIAL CONTINGENCIES : NOTE: This permit replaces expired permit 01192-2018INS.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Uni-Pump, Inc.
3070 Helsan Drive
Richfield, WI 53076

Contact Person: Steve Bennett
Phone: (262) 674-1522
Contractor Registration # IL1175 Exp. 11/20/2019

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File