



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 5006091
Permit # 01618-2018UPG
Request Rec'd 10/24/2018
Amended Date 04/03/2019 DS
Approval Date 10/24/2018 DS
Permit Expires 4/24/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Charlene Troyer (331) 251-7343</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Mac's #1225 320 Promenade Havana, IL 62644</p> <p>Contact: Samantha Payton (217) 243-1838</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 7) - 7,000

(b) Type of tanks:

(c) Type of piping: (TK # 7) Piping - Other Steel Riser

(d) Product to be stored in each tank: (TK # 7) - Gasoline - Premium

(e) Type of leak detection being used:

Tank: (TK # 7) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring Veeder Root TLS 350 micro sensor

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amending Permit to reflect Non-Discriminating Sump Sensor in the interstice. The TLS was hooked up incorrectly

Removing Spill Bucket part of this permit as it is the wrong model and we have several permits for this site that state the correct spill bucket will be installed on this tank. OPW ISC-3112D **NOTE: Active N.O.V. for overfill and spill containment is being addressed under permit 01675-2018UPG**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Jimmy Spiros

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File