



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4034390  
Permit # 00692-2019UPG  
Request Rec'd 04/03/2019  
Amended Date  
Approval Date 4/10/2019 DS  
Permit Expires 10/10/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  ML and RJ, Inc. 10 E. Northbrook Drive Dwight, IL 60420  Contact: Mohammad Latif (630) 768-2803	<b>(2) FACILITY</b> - name and address where tanks are located:  ML & RJ, Inc. 10 E. Northbrook Dr. Dwight, IL 60420  Contact: Rachel Sorensen (815) 584-2189
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2, 4) - 10,000, (TK # 3) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 2) - Gasoline - Premium, (TK # 3) - Gasoline - Regular, (TK # 4) - E-85*

(e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 4) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 4) Spill Contain Device - Single Wall Spill Bucket EBW 705 C1GKT Defender*

(h) *Overfill prevention devices: (TK # 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP, (TK # 4) Overfill Prev Device - Overfill Drop Tube Valve EBW 708 Auto Limiter*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Changing overfill prevention from ball float valve to drop tube valve assembly for ID #2-3-4. Equipment for ID #4 is E-85 compatible with documentation supplied. Installing E-85 compatible sump sensor by Veeder Root in ID #4 submersible containment sump and wiring for positive shut down. Existing ball float valves will be removed or disabled.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Total Petroleum Service Company  
2421 Washington Road  
Washington, IL 61571

Contact Person: Greg McCoy  
Phone: (309) 694-8224  
Contractor Registration # IL1079 Exp. 2/8/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File