



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6000120  
Permit # 00695-2019UPG  
Request Rec'd 04/11/2019  
Amended Date  
Approval Date 4/11/2019 DS  
Permit Expires 10/11/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  SRP CAP, Corporation 1810 Partridge Place Edwardsville, IL 62025  Contact: Cindy Bowling (618) 656-7765	<b>(2) FACILITY</b> - name and address where tanks are located:  Four-O Quick Shop 804 S. Main St. Troy, IL 62294  Contact: Cindy Bowling (618) 667-9514
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 4) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 4) - Gasoline*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : During a routine filter change, found the impact/shear valve body on the Reg UNL impact/shear valve at dispenser 1/2, to be defective. Will stop service to regular unleaded line, disconnect and remove dispenser 1/2 Reg UNL impact/shear valve. Furnish and install new OPW impact/shear valve for 1.5". Will restore service to Reg UNL line upon completion of installation and inspect for leaks. Schedule with OSFM to perform precision line testing for permit close out. **NOTE: If a UDC is not present one must be installed per 175.410 e) 2)**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Superior Acquisition LLC d/b/a Superior Equipment Company  
7525-A Sussex

Contact Person: Angela Hapgood  
Phone: (314) 644-6000

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File