



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2033279
Permit # 00719-2019UPG
Request Rec'd 04/14/2019
Amended Date
Approval Date 4/15/2019 DS
Permit Expires 10/16/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: BMD Group of Chicago, Inc. 550 W. North Avenue Lombard, IL 60148 Contact: Jshell Rawall (773) 990-0984	(2) <u>FACILITY</u> - name and address where tanks are located: BP Lombard 550 W. North Avenue Lombard, IL 60521 Contact: Raquel Wanderer (773) 990-0984
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : removing ball float and installing new vapor poppet on all 3 tanks. **NOTE: Site has existing drop tubes**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Reliable Pump Service and Maintenance
14007 S Bell Road Suite 228
Homer Glen, IL 60491

Contact Person: John Baio, Jr.
Phone: (815) 546-7867
Contractor Registration # IL002433 Exp. 10/4/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File