



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010101
Permit # 00722-2019UPG
Request Rec'd 04/15/2019
Amended Date
Approval Date 4/15/2019 DS
Permit Expires 10/16/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Waleed Ottman 27 East Ogden Avenue Westmont, IL 60559</p> <p>Contact: Waleed Ottmon (708) 257-5919</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Westmont Citgo 27 East Ogden Avenue Westmont, IL 60559</p> <p>Contact: Dean Mohammad (630) 942-5363</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 7,500, (TK # 2) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tanks to existing dispenser locations, (TK # 1, 2) Piping - Other Steel Riser, (TK # 1, 2) Piping - Other submersible pump, (TK # 1, 2) Piping - Shear Valves, (TK # 1, 2) Piping - Flex Connector Steel, (TK # 1, 2) Piping - Single Wall STP/Tanktop Sump Bravo B-407-RB*

(d) *Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 2) - Gasoline - Regular*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD, (TK # 1, 2) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in all submersible and dispenser sumps. NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640a) 1)

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3112D Edge*

(h) *Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : we are installing new piping double wall LCX, double wall spill buckets OPW 3112 D SERIES, over fill valves 71SO 400,new STP SUMPS BRAVO with new FE PETRO motor heads and also new dispenser sumps bravo **NOTES: Ball Floats will be removed/disabled at the time of this work. Old piping and sumps to be removed under permit 00709-2019REM.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Kiran Patibandla
Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2019

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File