



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1009874
Permit # 00780-2019UPG
Request Rec'd 04/18/2019
Amended Date
Approval Date 4/23/2019 DS
Permit Expires 10/23/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Fisa, Inc 1400 DeKalb Ave. De Kalb, IL 60178 Contact: Asif Quddus (815) 895-4145</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Sycamore Clark 227 E. State Street Sycamore, IL 60176 Contact: Asif Quddus (815) 895-4145</p>
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 12,000, (TK # 5) - 3,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4, 5) Piping - Fiberglass Double Wall A.O. Smith*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline - Regular, (TK # 5) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*


- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:** Replacing (2) existing faulty poly sumps with new Bravo fiberglass B7250-S1416 sumps for Wayne Ovation dispensers. Existing piping is Smith fiberglass double wall (2" primary / 3" secondary). Will be installing new stainless flexes and EBW shear valves in sumps. New 4' x 6' formed raised concrete islands to replace existing steel islands. New 4' wide U shaped steel bollards will be installed at ends of islands. Sumps to be hydro tested at inspection, and lines will be precision tested prior to final. Reconditioned Wayne Ovation dispensers will be installed.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc.
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Vicky Buhl
Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File