



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

| |
|---|
| <p>FOR OFFICE USE ONLY</p> <p>Facility # 2010027 Permit # 00810-2019UPG Request Rec'd 04/24/2019 Amended Date Approval Date 4/25/2019 Permit Expires 10/25/2019</p> |
|---|

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Mohammad Naviwala 2553 W. Chicago Avenue Chicago, IL 60622</p> <p>Contact: Mohammad Naviwala (773) 235-6500</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Clark 1810 W. 35th Street Chicago, IL 60609</p> <p>Contact: Mohammad Naviwala (773) 759-3314</p> |
|---|--|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 7,500*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Ball Valves, (TK # 2) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

| | |
|---|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| <p>Reliable Pump Service and Maintenance 14007 S Bell Road Suite 228 Homer Glen, IL 60491</p> | <p>Contact Person: John Baio, Jr. Phone: (815) 546-7867 Contractor Registration # IL002433 Exp. 10/4/2020</p> |

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File