



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5001144  
Permit # 00811-2019UPG  
Request Rec'd 04/26/2019  
Amended Date  
Approval Date 4/26/2019 FS  
Permit Expires 10/28/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Seeret Ayzel, Inc. 5 W. Cherry Street Winchester, IL 62694</p> <p>Contact: Surjit Singh (217) 358-8398</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Seeret Ayzel, Inc. 5 W. Cherry Street Winchester, IL 62694</p> <p>Contact: Kaur Sukhwinder (217) 358-8398</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000, (TK # 5, 6) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline - Regular, (TK # 5) - Gasoline - Premium, (TK # 6) - Diesel Fuel*
- (e) Type of leak detection being used:*

*Tank: (TK # 4, 5, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*

*Replacing failed ATG. This will correct at least part of the NOV to conduct the Annual Leak Detection Certification.*

*Piping:*

- (f) Corrosion Protection being used:*

*Tank:*

*Piping:*

- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pemco Service Company, Inc.  
1040 East Second Street  
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle  
Phone: (815) 265-7364  
Contractor Registration # IL1224 Exp. 2/26/2020

---

Sincerely,

□  
Fred Schneller

**cc:** Storage Tank Safety Specialist  
Division File