



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 3012554
Permit # 00507-2019UPG
Request Rec'd 03/19/2019
Amended Date 04/29/2019 DS
Approval Date 3/19/2019 DS
Permit Expires 9/19/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Fort Transfer Co 225 S Maple Po Box 457 Morton, IL 61550 Contact: Jim Foster (309) 263-2000	(2) FACILITY - name and address where tanks are located: Fort Transfer Co 225 S Maple Morton, IL 61550 Contact: Jason Eberle (309) 263-2000
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 2, 3) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 2, 3) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank: (TK # 2, 3) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c with CSLD

Piping: (TK # 2, 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1DV

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amending the permit to install a TLS 300C not a TLS 350 plus

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File