



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2013070
Permit # 00815-2019REM
Request Rec'd 04/25/2019
Amended Date
Approval Date 4/29/2019 DS
Permit Expires 10/29/2019

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>North Shore University Health System 1301 Central Street Evanston, IL 60201</p> <p>Contact: Patrick Burke (847) 570-1018</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>North Shore University Health System 9600 Gross Point Road Skokie, IL 60076</p> <p>Contact: Dave Ramitar (847) 933-6750</p>
---	--

(3) **REMOVAL OF PIPING:**

(a) *Description/location of piping being removed:*

(b) *Which tank(s) are associated with the piping being removed: (TK # 5) - 20,000*

(c) *Reason of piping being removed:*

(d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Abandoning (2) existing transition sumps and partial piping runs as the hospital main gas feed runs over the top of the existing transition sumps. Any accessible underground piping will be removed. **NOTE: An abandonment permit application MUST be submitted.**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
1111 West Dundee Road
Wheeling, IL 600903936

Contact Person: Warren Cherner
Phone: (847) 465-4000
Contractor Registration # IL102 Exp. 2/7/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File