



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2041586
Permit # 00860-2019UPG
Request Rec'd 04/29/2019
Amended Date
Approval Date 5/1/2019 DS
Permit Expires 11/1/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Costco Wholesale Corporation P.O. Box 35005 Seattle, WA 98124</p> <p>Contact: Jay S.Grubb (206) 313-8100</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Costco Wholesale #342 1332 South Route 59 Naperville, IL 60564</p> <p>Contact: Sandra Delaquila (630) 328-2900</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 20,000, (TK # 4) - 1,500*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 2, 3) Piping - Flexible Double Wall OPW Flexworks for siphon line from tank #2 to new 30,000 tank that's going in under the install permit and also to branch off of the existing premium lines at the existing dispenser 20/21 to feed the 5 new dispensers being installed. (TK # 3) Piping - Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 3) Piping - Ball Valves, (TK # 3) Piping - Shear Valves, (TK # 3) Piping - Flex Connector Steel, (TK # 4) Piping - Fiberglass Double Wall Ameron from the existing Lubrizol piping to branch into the new product piping.*

(d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline, (TK # 4) - Lubrizol - Fuel Additive*

(e) *Type of leak detection being used:*

Tank: (TK # 1, 2, 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 1, 2, 3, 4) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus

Piping: (TK # 1, 2, 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 1, 2, 3, 4) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in all submersible and dispenser sumps, (TK # 2) Leak Detect - Piping - Siphon Bar for piping from tank #2 to the new 30,000 tank. NOTE: Please refer to our rules pertaining to siphon bars, section 175.450 c) Siphon Bars. Siphon bars that are used to transfer petroleum and hazardous substances between tanks by means of gravity or negative atmospheric pressure shall be permitted subject to the following requirements:

- 1) The height of the tops of all tanks connected by the siphon bars shall be within 6 inches of each other;*
- 2) Piping shall meet the requirements of Section 175.420; and*
- 3) Release detection methods for tanks and piping shall be of a type approved for tanks connected by siphon bars, in accordance with Section 175.630.*

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 3) Corrosion Prot - Piping - Flexible Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket OPW FibreTite Multi-port*

(h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C, (TK # 1, 2, 3, 4) Overfill Prev Device - Overfill Alarm Veeder Root TLS 450plus NOTE: Existing ball floats MUST be removed or disabled*

(i) *Manway accessible at grade:*


- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Expanding existing canopy to install (5) new dispensers and islands. Existing petroleum tanks get new TLS450Plus, fill manholes, and drop tubes. We will also be installing a new 30,000 gallon tank on an install permit. Existing tank #2 will be siphoned to the new tank. Existing tank #3 (premium) will have new piping from existing dispenser #20/21 to the (5) new dispensers. Existing additive tank will be piped to the new tank. Installing new VST green machine and kiosk.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File