



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

## Piping removal only

FOR OFFICE USE ONLY  
Facility # 3-009229  
Permit # 01209-2008REM  
Request Rec'd 07/22/2008  
Amended Date  
Approval Date 7/22/2008 JC  
Permit Expires 1/22/2009

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Gold Star FS Inc Box 79 Cambridge, IL 61238  Contact: Dana Robinson (309) 937-5465	<b>(2) FACILITY</b> - name and address where tanks are located:  Annawan Fuel 24 Rt 78 - North Canal St Annawan, Henry Co., IL  Contact: Van De Velde Dave (309) 937-3369
---	---

**(3) REMOVAL OF TANKS:**

- (a) Number and size of tanks being removed:* (TK # 1, 2, 3) - 10,000 gallons
  - (b) Product stored in each tank:* (TK # 1) - Diesel Fuel, (TK # 2, 3) - Gasoline
  - (c) Reason of tanks being removed:* Piping removal only. Tanks will remain in place.
  - (d) If tank(s) is leaking, indicate IEMA incident number:*
  - (e) Date each tank was last used:* (TK # 1), (TK # 2), (TK # 3)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**
- (5) SPECIAL CONTINGENCIES: This permit is for the removal of the existing piping only. The tanks will remain in place and will have new piping / dispensers installed in different piping trenches under a separate upgrade permit. See also permit #01176-2008INS for reference to the installation of tank and piping for tank #4.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Pipeco, Inc. 610 29th Street	Contact Person: Art Wentworth Phone:  Contractor Registration #    Exp.
--	--

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 6/07)