



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 3-011091
Permit # 01200-2008INS
Request Rec'd 07/21/2008
Amended Date
Approval Date 7/22/2008 JC
Permit Expires 1/22/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Moline City Of 619 16Th St Moline, IL 61265</p> <p>Contact: George Stevens (309) 797-0751</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Municipal Ser Garage 3635 4Th Ave Moline, Rock Island Co., IL</p> <p>Contact: George Stevens (309) 797-0751</p>
---	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:* (TK # 6) - 10,000 gallons
- (b) Type of tanks:* (TK # 6) - (Installing) XERXES double wall fiberglass
- (c) Type of piping:* (TK # 6) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible
- (d) Product to be stored in each tank:* (TK # 6) - E-85
- (e) Type of leak detection being used:*
 - Tank:** (TK # 6) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge, (TK # 6) - (Installing) Veeder Root TLS 350 Plus Interstitial tank sensor
 - Piping:** (TK # 6) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors at the submersible sump and dispenser sump, (TK # 6) - (Installing) Veeder Root TLS 350 Plus line leak detector
- (f) Corrosion Protection being used:*
 - Tank:** (TK # 6) - (Installing) Fiberglass
 - Piping:** (TK # 6) - (Installing) Non-corrosive flexible
- (g) Spill containment devices:*
- (h) Overfill prevention devices:*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	<p>Contact Person: Rob Vyncke Phone: Contractor Registration # IL-981 Exp. 04/25/2010</p>
---	---

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)