



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-044086  
Permit # 01145-2008INS  
Request Rec'd 07/02/2008  
Amended Date  
Approval Date 7/15/2008 DS  
Permit Expires 1/15/2009

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  City of Lake Forest 110 E Laurel Ave Lake Forest, IL 60045  Contact: Max Slankard (708) 234-2600	<b>(2) FACILITY</b> - name and address where tanks are located:  CLF Municipal Service Facility 801 North Field Drive Lake Forest, Lake Co., IL  Contact:
---	---

**(3) INSTALLATION OF TANKS:**

**(a) Number and size of tanks being installed:** (TK # 1, 2) - 20,000 gallons

**(b) Type of tanks:** (TK # 1, 2) - (Installing) XERXES double wall fiberglass

**(c) Type of piping:** (TK # 1, 2) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass

**(d) Product to be stored in each tank:** (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel

**(e) Type of leak detection being used:**

**Tank:** (TK # 1, 2) - (Installing) OPW Site Sentinel 2 interstitial tank sensor, (TK # 1, 2) - (Installing) OPW Site Sentinel 2 automatic tank gauge

**Piping:** (TK # 1) - (Installing) Red Jacket FX1V mechanical line leak detector, (TK # 1, 2) - (Installing) OPW Site Sentinel 1 single float interstitial piping sump sensors in all dispenser and submersible sumps, (TK # 2) - (Installing) Red Jacket FX1DV mechanical line leak detector

**(f) Corrosion Protection being used:**

**Tank:**

**Piping:** (TK # 1, 2) - (Installing) containment sump

**(g) Spill containment devices:**

**(h) Overfill prevention devices:**

**(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:** Contractor changed type of piping leak detection.

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>     Contact Person: Phone: (630) 375-6121  Contractor Registration # IL-1594 Exp.
---

Sincerely,



cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)