

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-036850
Permit # 01192-2008UPG
Request Rec'd 07/21/2008
Amended Date
Approval Date 7/21/2008 JC
Permit Expires 1/21/2009

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

` /	IER OF TANKS - Corporation, partnership, or other ss entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
5508 Lon	vel Centers, L.L.C. nas Road, P. O. Box 10146 e, TN 37909	Pilot Travel Center #236 301 Ridge Road Minooka, Grundy Co., IL
Contact:	Ted Asbury (865) 588-7488	Contact: Alford Mark (423) 588-7488

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) 20,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 4) (Installing) Ameron Dualoy 3000/LCX double wall fiberglass from the existing submersible pump to the first two (western most) dispensers. The existing dispenser tops will be re-used. The existing two short piping runs that come off of the existing main dispenser supply line will be capped off along with the existing short section that comes off of the submersible pump to the main supply line that leads to the blending pump. Tank #4 is converting to ultra low sulfur diesel and will no longer be part of the "bio-diesel system" (tanks 5,6 and 10).
- (d) Product to be stored in each tank: (TK # 4) Diesel Fuel
- (e) Type of leak detection being used:

Tank:

Piping: (TK # 4) - (Installing) Veeder Root non discriminating stand alone dispenser pan sensors at the two ultra low sulfur diesel dispenser sumps only (the two western most dispensers), (TK # 4) - Existing interstitial monitoring at the submersible sump, (TK # 4) - Existing line leak detector

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
	Contact Person: Steve Tuttle

Phone: (630) 588-1198

Contractor Registration # IL-2087 Exp.

Sincerely,

Jame of Coffey

Fire Department -Office Coordinator -Division File (Rev. - 1/98)