



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY

Facility # 6-044099
 Permit # 01171-2008INS
 Request Rec'd 07/15/2008
 Amended Date
 Approval Date 7/16/2008 JC
 Permit Expires 1/16/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Supervalu 10461 Manchester Road St. Louis, IL 63122</p> <p>Contact:</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Shop & Save 2122 Troy Road, Edwardsville, Madison Co., IL</p> <p>Contact:</p>
--	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 1) - 20,000 gallons, (TK # 2, 3) - 8,000 gallons, (TK # 4) - 12,000 gallons
- (b) **Type of tanks:** (TK # 1, 2, 3, 4) - (Installing) XERXES double wall fiberglass brine filled
- (c) **Type of piping:** (TK # 1, 2, 3, 4) - (Installing) A.P.T. Poly Tech P200SC double wall flexible, including a siphon bar between tanks 1 & 2, and also a future use product line from tank #2 to the northern most dispenser (this future use piping line will be capped off at this time, and may be used for E-85 at a future date).
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel
- (e) **Type of leak detection being used:**
 - Tank:* (TK # 1, 2, 3, 4) - (Installing) Veeder Root TLS-350 Plus Dual stage hydrostatic interstitial tank sensor, (TK # 1, 2, 3, 4) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge with CSLD
 - Piping:* (TK # 1, 3, 4) - (Installing) Veeder Root TLS 350 Plus line leak detector (tank #2 will be siphoned to tank #1; consequently, tank #2 will not have a submersible pump or line leak detector. The piping sump at tank #2; however, will have an interstitial sensor), (TK # 1, 2, 3, 4) - (Installing) Veeder Root TLS 350 discrim cont sump interstitial sensor at all submersible sumps - including the sump at tank #2, and all dispenser sumps
- (f) **Corrosion Protection being used:**
 - Tank:* (TK # 1, 2, 3, 4) - (Installing) Fiberglass
 - Piping:* (TK # 1, 2, 3, 4) - (Installing) Non-corrosive flexible
- (g) **Spill containment devices:**
- (h) **Overflow prevention devices:**

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p> <p style="text-align: right;">Contact Person: Rick McKay Phone: Contractor Registration # IL-1502 Exp. 02/10/2010</p>
--

Sincerely,

