

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL **Division of Technical Services**

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 4-043703 Permit # 01164-2008INS Request Rec'd 07/15/2008 Amended Date Approval Date 7/15/2008 JC Permit Expires 1/15/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Meijer Great Lakes Limited Partnership 2929 Walker Avenue, North West Grand Rapids, MI 49534	Meijer Gas Station #247 2500 South Philo Rd. Urbana, Champaign Co., IL
Contact: Lyle L. Livasy	Contact:

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1, 4) 8,000 gallons, (TK # 2) 20,000 gallons, (TK # 3, 5) 6,000 gallons
- (b) Type of tanks: (TK # 1, 2, 3, 4, 5) (Installing) XERXES double wall fiberglass brine filled
- (c) Type of piping: (TK # 1, 2, 3, 4, 5) (Installing) A.O. Smith double wall fiberglass
- (d) Product to be stored in each tank: (TK # 1, 2) Gasoline, (TK # 3) Diesel Fuel, (TK # 4) Bio-Diesel, (TK # 5) E-85
- (e) Type of leak detection being used:

Tank: (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS350 automatic tank gauge, (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor

Piping: (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all submersible sumps and at all dispenser sumps

(f) Corrosion Protection being used:

Tank: (TK # 1, 2, 3, 4, 5) - (Installing) Fiberglass **Piping:** (TK # 1, 2, 3, 4, 5) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(7)	PERSON,	FIRM (<u> JR COMP</u>	ANY PERI	FORMING	WORK:

Contact Person: Andy Mercer

Phone:

Janu J Coffey

Contractor Registration # IL-002211 Exp. 02/28/2009

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department -

(Rev. - 1/98)

Office Coordinator -Division File