



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-018765
Permit # 01130-2008UPG
Request Rec'd 07/02/2008
Amended Date
Approval Date 7/10/2008 DS
Permit Expires 1/10/2009

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE**

APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Git-N-Go Convenience Stores, Inc. 2716 Indiana Avenue Des Moines, IA 50315 Contact: Pete Klindt (515) 288-8565	(2) FACILITY - name and address where tanks are located: Git-N-Go #8 203 1st Avenue West Coal Valley, Rock Island Co., IL Contact: Pete Klindt (515) 288-8565
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:** (TK # 1, 2, 3, 4, 5) - 6,000 gallons
 - (b) Type of tanks:**
 - (c) Type of piping:** (TK # 1, 2, 3, 4, 5) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible
 - (d) Product to be stored in each tank:** (TK # 1, 2, 3, 4, 5) - Gasoline
 - (e) Type of leak detection being used:**
 - Tank:** (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge
 - Piping:** (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS 350 Plus line leak detector, (TK # 1, 2, 3, 4, 5) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors in all dispenser sumps and all submersible sumps
 - (f) Corrosion Protection being used:**
 - Tank:** (TK # 1, 2, 3, 4, 5) - Existing impressed current cathodic protection, (TK # 1, 3) - Existing interior lining
 - Piping:** (TK # 1, 2, 3, 4, 5) - (Installing) containment sumps at all dispensers, (TK # 1, 2, 3, 4, 5) - (Installing) Non-corrosive flexible
 - (g) Spill containment devices:**
 - (h) Overfill prevention devices:**
 - (i) Manway accessible at grade:**
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Mike Worthington Phone: (515)264-4329 Contractor Registration # Exp.
--

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)