



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Piping removal only

FOR OFFICE USE ONLY
Facility # 7-028263
Permit # 01102-2008REM
Request Rec'd 07/03/2008
Amended Date
Approval Date 7/3/2008 JC
Permit Expires 1/3/2009

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Karco, Inc. 1405 Salem Road, Mount Vernon, IL 62864 Contact: Ronald J. Kruep	(2) FACILITY - name and address where tanks are located: One Stop #19 1300 West Main Street West Frankfort, Franklin Co., IL Contact: Joe Beveridge (618) 237-5964
--	---

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1, 2, 3) - 10,000 gallons
 - (b) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
 - (c) *Reason of tanks being removed:* **See contingencies section. This is a piping removal only. The tanks will remain.**
 - (d) *If tank(s) is leaking, indicate IEMA incident number:*
 - (e) *Date each tank was last used:* (TK # 1, 2, 3) - 04/15/2008
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** This permit is for product line removal only. The tanks will remain in ground for future use. The station will be remodeled on a future permit. The product lines need to be removed for building and island demolition.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: United Petroleum Service, Inc. 1458 Collins Street	Contact Person: Harvey Stokes Phone: Contractor Registration # Exp.
--	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 6/07)