



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-044025
Permit # 01099-2008ABN
Request Rec'd 07/03/2008
Amended Date
Approval Date 7/3/2008 JC
Permit Expires 1/3/2009

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Cicero School District #99 5110 W 24Th St Cicero, IL 60650 Contact: Kalita-Restko Donna (708) 863-4856	(2) FACILITY - name and address where tanks are located: Goodwin Elementary School 2625 S. Austin Boulevard Cicero, Cook Co., IL Contact:
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 1) - 10,000 gallons
(b) *Location of tanks being abandoned:* see site plan and contingency section.

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES:** Tank is located too close to the building's foundation with sand backfill around the tank and may compromise the integrity of the structure if removed. A copy of the site assessment is on file and a copy of the structural engineer statement is also on file.
- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: R. W. Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Ann Collins Phone: (708) 458-6868 Contractor Registration # IL-772 Exp.
--	---

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)