



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 4-044048
Permit # 00922-2008INS
Request Rec'd 06/02/2008
Amended Date
Approval Date 6/9/2008 JC
Permit Expires 12/9/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Pilot Travel Centers, L.L.C. 5508 Lonas Road, P. O. Box 10146 Knoxville, TN 37909 Contact: Ted Asbury (865) 588-7488	(2) FACILITY - name and address where tanks are located: Pilot Travel Center 815 Highway Route 24W Gilman, Iroquois Co., IL Contact:
--	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 1) - 9,000 gallons, (TK # 2) - 16,000 gallons, (TK # 3, 4, 5, 6) - 20,000 gallons
- (b) **Type of tanks:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) XERXES double wall fiberglass
- (c) **Type of piping:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass (there will be a future use siphon bar between tanks 5 and 6, and also a present use siphon bar between tanks 3, 4, and 5. Tank #4 will not have a submersible pump or line leak detector installed since it is going to be used as a slave tank. It will, however, have an interstitial sensor at the tank piping sump).
- (d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline, (TK # 3, 4, 5) - Diesel Fuel, (TK # 6) - Bio-Diesel
- (e) **Type of leak detection being used:**
Tank: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS350 automatic tank gauge (probes will be used for inventory purposes only), (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS 350 interstitial tank sensor for leak detection.
Piping: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all tank sumps, at the two remote fuel supply line ball valve shut-off manhole sumps, and at the bio-diesel injection / by-pass sump, (TK # 1, 2) - (Installing) FE Petro STP-MLD mechanical line leak detector, (TK # 3, 5) - (Installing) FE Petro STP-MLD-HCD mechanical line leak detector, (TK # 6) - (Installing) European Suction
- (f) **Corrosion Protection being used:**
Tank: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Fiberglass
Piping: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Fiberglass
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp.
--

Sincerely,

