



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-022701
Permit # 00908-2008ENT
Request Rec'd 06/05/2008
Amended Date
Approval Date 6/5/2008 JC
Permit Expires 12/5/2008

Permit for ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Amoco Research Center(F-3/EHS) 150 West Warrenville Road Naperville, IL 60563 Contact: James L Saylor (630) 420-4874	(2) FACILITY - name and address where tanks are located: BP Naperville Campus 150 West Warrenville Road,P.O. Box 3011 Naperville, Du Page Co., IL Contact: James Saylor (630) 420-4874
--	---

(3) ENTRY OF TANKS:

- (a) **Number and size of tanks being entered:** (TK # 15, 16) - 10,000 gallons, (TK # 66, 67, 68, 69, 70, 71, 72, 73, 74, 80) - 2,000 gallons, (TK # 96, 97, 98, 99, 100, 101) - 6,000 gallons
- (b) **Type of tanks:**
- (c) **Product stored in each tank:** (TK # 15, 16, 66, 67, 68, 69, 70, 71, 74, 96, 97, 98, 99, 100, 101) - Gasoline, (TK # 72, 80) - Diesel Fuel, (TK # 73) - Kerosene
- (d) **Reason for tanks being entered:**
- (e) **Manway accessible at grade:** Contractor states there are existing manways.

- (4) **The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). **Contractor states there are existing manways at grade. Contractor is entering to clean the tanks for removal coinciding with permit #00754-2008REM.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Jim Veverka Phone: Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)