

## Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Pilot Travel Centers, L.L.C. 5508 Lonas Road, P. O. Box 10146 Knoxville, TN 37909	Pilot Travel Center #299 1522 West Market Street Bloomington, McLean Co., IL
Contact: Ted Asbury (865) 588-7488	Contact: Steve Smith (309) 827-7867

## (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 9) 20,000 gallons
- (b) Type of tanks: (TK # 9) (Installing) Highland Tank Titan Jacketed double wall steel
- (c) Type of piping: (TK # 9) (Installing) A.O. Smith double wall fiberglass siphon bar that will connect from tank #9 to tank #5 and #6
- (d) Product to be stored in each tank: (TK # 9) Diesel Fuel
- (e) Type of leak detection being used:
  - *Tank:* (TK # 9) (Installing) Veeder Root TLS 350 interstitial tank sensor, (TK # 9) (Installing) Veeder Root TLS350 automatic tank gauge (the existing console will be used)
  - *Piping:* (TK # 9) (Installing) Veeder Root TLS350 interstitial piping sump sensors at each end of the two siphon bars (tank sump at tank #9, Tank sump at tank #5, and tank sump at tank #6).

## (f) Corrosion Protection being used:

Tank: (TK # 9) - (Installing) Highland Tank Titan non-corrosive secondary jacket

Piping: (TK # 9) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

# (5) GENERAL REQUIREMENTS:

## (6) <u>SPECIAL CONTINGENCIES</u>:

# (7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Phone: (815) 265-7364

Contractor Registration # IL-1224 Exp.

Sincerely,

Jame & Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)