



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-018687
Permit # 00850-2008UPG
Request Rec'd 05/13/2008
Amended Date
Approval Date 6/2/2008 JC
Permit Expires 12/2/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ameren / Cilco 7800 South Cilco Lane Bartonville, IL 61607 Contact: William Henning (309) 633-2457	(2) FACILITY - name and address where tanks are located: E D Edwards Power Plant 7800 South Cilco Lane Bartonville, Peoria Co., IL Contact: Mark Davis (309) 633-2861
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 9) - 20,000 gallons
- (b) *Type of tanks:* (TK # 9) - Existing single wall steel
- (c) *Type of piping:* (TK # 9) - Existing single wall above ground steel
- (d) *Product to be stored in each tank:* (TK # 9) - Fuel Oil
- (e) *Type of leak detection being used:*
 - Tank:** (TK # 9) - (Installing) Veeder Root TLS350 automatic tank gauge for inventory control and leak detection.
 - Piping:** Contractor states the existing piping is all above ground.
- (f) *Corrosion Protection being used:*
 - Tank:** Contractor states an impressed current system will be installed through a separate permit.
 - Piping:** Contractor states all piping is above ground
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)