



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 2-043278
Permit # 00580-2008REM
Request Rec'd 04/16/2008
Amended Date 05/23/2008
Approval Date 4/16/2008 DS
Permit Expires 10/16/2008

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: BP Products North America, Inc. DO NOT USE THIS OWNER ID, Warrenville, IL 60555 Contact: Jay Richey	(2) FACILITY - name and address where tanks are located: Midwest Welding Supply Company 2205 S. Halsted Street Chicago Heights, Cook Co., IL Contact:
---	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed:** (TK # 1, 2, 3, 4) - 2,500 gallons, (TK # 5, 6, 7) - 1,000 gallons
- (b) Product stored in each tank:** (TK # 1, 2, 3, 4, 5, 6, 7) - **Unknown petroleum**
- (c) Reason of tanks being removed:** **No longer in use.**
- (d) If tank(s) is leaking, indicate IEMA incident number:** **060352 and 931907**
- (e) Date each tank was last used:** (TK # 1, 2, 3, 4, 5, 6, 7) - **Prior to 12/31/1973**

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

- (5) SPECIAL CONTINGENCIES: Amendment request (05/23/08) to declare the product in tanks as an "unknown petroleum" rather than "gasoline". Date tanks were last used was prior to 12/31/1973. The facility has two incident numbers: 20060352 and 19931907.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: R. W. Collins Company 7225 West 66th Street	Contact Person: Ann Collins Phone: Contractor Registration # Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 6/07)