



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 3-018766
Permit # 00575-2008UPG
Request Rec'd 04/15/2008
Amended Date 05/20/2008
Approval Date 4/16/2008 JC
Permit Expires 10/16/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Git-N-Go Convenience Stores, Inc. 2716 Iindanda Avenue Des Moines, IA 50315 Contact: Pete Klindt (515) 288-8565	(2) FACILITY - name and address where tanks are located: Git N Go #12 4319 6th Avenue Rock Island, Rock Island Co., IL Contact: Pete Klindt (515) 288-8565
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 8,000 gallons, (TK # 3) - 12,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3) - Existing single wall steel
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible to replace all existing product piping. **Also replacing all vent piping with 2" single wall fiberglass.**
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*
Tank: (TK # 1, 2, 3) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge
Piping: (TK # 1, 2, 3) - (Installing) Veeder Root TLS 350 Plus line leak detector, (TK # 1, 2, 3) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors at all submersible sumps and at all dispenser sumps
- (f) *Corrosion Protection being used:*
Tank: (TK # 1, 2, 3) - Existing impressed current cathodic protection
Piping: (TK # 1, 2, 3) - (Installing) Non-corrosive flexible
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Mike Worthington Phone: 515-264-4329 Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)