

# Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Wal-mart Stores, Inc. 702 S. W. 8th Street, Dept. 8916, Attention: Licensing Bentonville, AR 72716-0500	Wal-Mart Food Distribution Center #6059 3801 E. Highway 50 Olney, Richland Co., IL
Contact: Pam Wilmott (479) 204-2280	Contact: Rick Williams (618) 393-7500

# (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 4) 20,000 gallons
- (b) Type of tanks: (TK # 4) (Installing) XERXES double wall fiberglass
- (c) Type of piping: (TK # 4) (Installing) A.O. Smith double wall fiberglass that will also include a siphon bar between this new tank and tank #1
- (d) Product to be stored in each tank: (TK # 4) Diesel Fuel
- (e) Type of leak detection being used:

*Tank:* (TK # 4) - (Installing) Veeder Root TLS 350 interstitial tank sensor, (TK # 4) - Existing automatic tank gauging console to be used; however, a new probe will be installed in this tank for inventory purposes.

- *Piping:* (TK # 4) (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 4) (Installing) Veeder Root TLS350 interstitial piping sump sensors at the submersible sumps and both dispenser sumps.
- (f) Corrosion Protection being used:

Tank: (TK # 4) - (Installing) Fiberglass

Piping: (TK # 4) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

# (5) GENERAL REQUIREMENTS:

# (6) <u>SPECIAL CONTINGENCIES</u>:

# (7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Phone: (309) 347-1819

Contractor Registration # IL-1293 Exp.

Sincerely,

Janu J Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)